

# Voda – Teplo – Světlo, s. r. o.

Blanenská 84, 679 02 Rájec - Jestřebí

IČO: 25574434, DIČ: CZ25574434

Zapsán: KS BRNO, oddíl C, vložka 34209

---

PIS PECHAL, s.r.o.  
Projektové a inženýrské služby  
Lidická 42  
602 00 Brno

V Rájci – Jestřebí 20.10.2014

Věc: Vyjádření k přeložce sítí na stavbu II/377 Rájec-Jestřebí, most 377-008, okružní křižovatka

Společnost **Voda-Teplo-Světlo, s.r.o.**, provozovatel vodovodu a kanalizace ve městě Rájec-Jestřebí, nepožaduje na stavbě „II/377 Rájec-Jestřebí, most 377-008, okružní křižovatka“ přeložení vodovodního a kanalizačního řadu v případě zachování současné nivelety vozovky.



Voda-Teplo-Světlo  
s.r.o.  
Blanenská 84  
679 02 Rájec-Jestřebí

Ing. Petr Klimek, jednatel

**Od:** Martina Varmužová <varmuzova@pechal.cz>  
**Odesláno:** 21. října 2014 12:55  
**Komu:** "k >> Jan Krakovič"  
**Přílohy:** most 377-008.pdf

----- Přeposlaná zpráva -----

**From:-** Tue Oct 21 10:13:14 2014  
**X-Account-Key:**account1  
**X-UIDL:**1353934878.93  
**X-Mozilla-Status:**0001  
**X-Mozilla-Status2:**00000000  
**X-Mozilla-Keys:**  
**Return-Path:**<[petr.klimek@vodarajec.cz](mailto:petr.klimek@vodarajec.cz)>  
**Received:**from zoner.com (r1.zoner.com [217.198.120.27]) by imap9 (Cyrus v2.3.14) with LMTPA; Tue, 21 Oct 2014 07:57:49 +0200  
**X-Sieve:**CMU Sieve 2.3  
**Received:**from localhost (localhost [127.0.0.1]) by zoner.com (Postfix) with ESMTP id 1906A4192AF3 for <[varmuzova@pechal.cz](mailto:varmuzova@pechal.cz)>; Tue, 21 Oct 2014 07:57:49 +0200 (CEST)  
**X-Virus-Scanned:**amavisd-new at zoner.com  
**Received:**from zoner.com ([127.0.0.1]) by localhost (relay.zoner.com [127.0.0.1]) (amavisd-new, port 10024) with ESMTP id xzN0r0gJvqBX for <[varmuzova@pechal.cz](mailto:varmuzova@pechal.cz)>; Tue, 21 Oct 2014 07:57:48 +0200 (CEST)  
**Received:**from server.dreamcloud.cz (server.dreamcloud.cz [46.149.115.114]) by zoner.com (Postfix) with ESMTP id 6C58B426AD03 for <[varmuzova@pechal.cz](mailto:varmuzova@pechal.cz)>; Tue, 21 Oct 2014 07:57:48 +0200 (CEST)  
**Received:**from localhost (localhost [127.0.0.1]) by server.dreamcloud.cz (Postfix) with ESMTP id 01834C040CA for <[varmuzova@pechal.cz](mailto:varmuzova@pechal.cz)>; Tue, 21 Oct 2014 07:57:28 +0200 (CEST)  
**X-Virus-Scanned:**Debian amavisd-new at server.dreamcloud.cz  
**Received:**from server.dreamcloud.cz ([127.0.0.1]) by localhost (server.dreamcloud.cz [127.0.0.1]) (amavisd-new, port 10024) with ESMTP id wz0g4NT7fF42 for <[varmuzova@pechal.cz](mailto:varmuzova@pechal.cz)>; Tue, 21 Oct 2014 07:57:07 +0200 (CEST)  
**Received:**from HeppMPC (unknown [46.149.115.52]) (Authenticated sender: [petr.klimek@vodarajec.cz](mailto:petr.klimek@vodarajec.cz)) by server.dreamcloud.cz (Postfix) with ESMTPA id C9C9CC040C8 for <[varmuzova@pechal.cz](mailto:varmuzova@pechal.cz)>; Tue, 21 Oct 2014 07:57:05 +0200 (CEST)  
**Message-ID:**<5D8C04F301AE4D0A89E58CA032C7FA6A@HeppMPC>  
**From:**Ing. Petr Klimek <[petr.klimek@vodarajec.cz](mailto:petr.klimek@vodarajec.cz)>  
**To:**[varmuzova@pechal.cz](mailto:varmuzova@pechal.cz)  
**Subject:**  
**Date:**Tue, 21 Oct 2014 07:48:00 +0200  
**MIME-Version:**1.0  
**Content-Type:**multipart/mixed; boundary="----=\_NextPart\_000\_0011\_01CFED03.56443870"  
**X-Priority:**3  
**X-MSMail-Priority:**Normal  
**X-Mailer:**Microsoft Outlook Express 6.00.2900.5931  
**Disposition-Notification-To:**"Ing. Petr Klimek" <[petr.klimek@vodarajec.cz](mailto:petr.klimek@vodarajec.cz)>  
**X-MimeOLE:**Produced By Microsoft MimeOLE V6.00.2900.6157

Dobrý den paní inženýrko,  
vyjádření k sítím zasílám v příloze.

Pokud jde o napojení se na vpust' na rameni křižovatky ve směru na Blansko - ta není naše, patří SÚS Jm kraje. Včera jsem se na ni díval a je totálně zanešená. Kam je dopojena, to bohužel v naší dokumentaci nemáme podchyceno, ale předpokládám, že do naší kanalizace. Nejlépe by bylo kontaktovat SÚS a požádat je o uvedení vpustí do řádného stavu.

Přeji pěkný den

**Voda-Teplo-Světlo, s.r.o.**

Ing. Petr Klimek

Blanenská 84

679 02 Rájec-Jestřebí

Tel: 734 276 470

[petr.klimek@vodarajec.cz](mailto:petr.klimek@vodarajec.cz)