

| | | TABULKA MÍSTNOSTÍ | | | | | | | | | | | |
|-----------------|-----------------------------------|-------------------|-----------------|-----------------|--------|--------|-------|--------|--------|------------------|-----------------|----------|--|
| číslo místn. | Název místnosti | Plocha místn. | Výška místn. | Objem místn. | Výměna | Přívod | Odvod | Podtl. | Přetl. | č.zař. přívod | č.zař. odvod | Poznámka | |
| | | m2 | m | m3 | x / h | m³h⁻¹ | m³h⁻¹ | % | % | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | Zařízení číslo 1 - Větrání CHÚC B | | | | | | | | | | | | |
| 128 | výtahová šachta | 6,60 | 0,00 | 0 | 15,0 | 0 | 0 | 100 | 01.led | | | | |
| 129 | výtahová šachta | 6,60 | 0,00 | 0 | 15,0 | 0 | 0 | 100 | 01.led | | | | |
| 130 | chodba | 79,80 | 4,35 | 347 | 15,0 | 5 210 | 0 | 100 | 01.led | | | | |
| | | | | | | | | | | | | | |
| 214b | chodba | 25,50 | 3,35 | 85 | 15,0 | 1 290 | 0 | 100 | 01.led | | | | |
| 214c | chodba | 31,00 | 3,35 | 104 | 15,0 | 1 560 | 0 | 100 | 01.led | | | | |
| 230 | schodiště | 24,60 | 4,45 | 109 | 15,0 | 1 650 | 0 | 100 | 01.led | | | | |
| 231 | chodba | 9,90 | 3,35 | 33 | 15,0 | 500 | 0 | 100 | 01.led | | | | |
| 232 | výtahová šachta | 6,60 | 0,00 | 0 | 15,0 | 0 | 0 | 100 | 01.led | | | | |
| 233 | výtahová šachta | 6,70 | 0,00 | 0 | 15,0 | 0 | 0 | 100 | 01.led | | | | |
| | | | | | | | | | | | | | |
| 319a | chodba | 33,40 | 3,50 | 117 | 15,0 | 1 760 | 0 | 100 | 01.led | | | | |
| 319b | chodba | 26,40 | 3,50 | 92 | 15,0 | 1 390 | 0 | 100 | 01.led | | | | |
| 320 | výtahová šachta | 6,60 | 0,00 | 0 | 15,0 | 0 | 0 | 100 | 01.led | | | | |
| 321 | výtahová šachta | 6,70 | 0,00 | 0 | 15,0 | 0 | 0 | 100 | 01.led | | | | |
| 330 | schodiště | 24,30 | 3,90 | 95 | 15,0 | 1 430 | 0 | 100 | 01.led | | | | |
| 331 | chodba | 11,70 | 3,50 | 41 | 15,0 | 620 | 0 | 100 | 01.led | | | | |
| | | | | | | | | | | | | | |
| 400 | schodiště | 14,50 | 3,20 | 46 | 15,0 | 700 | 0 | 100 | 01.led | | | | |
| 401 | schodiště | 10,40 | 3,20 | 33 | 15,0 | 500 | 0 | 100 | 01.led | | | | |
| 402 | chodba | 37,60 | 3,20 | 120 | 15,0 | 1 810 | 0 | 100 | 01.led | | | | |
| 407 | výtahová šachta | 6,60 | 18,28 | 121 | 15,0 | 1 810 | 0 | 100 | 01.led | | | | |
| 408 | výtahová šachta | 6,70 | 18,28 | 122 | 15,0 | 1 840 | 0 | 100 | 01.led | | | | |
| 409 | chodba | 18,80 | 3,20 | 60 | 15,0 | 910 | 0 | 100 | 01.led | | | | |
| | | | | | | | | | | | | | |
| | | | | Součet | | 22 980 | 0 | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | Zařízení číslo 2 - Větrání CHÚC B | | | | | | | | | | | | |
| 110a | chodba+schodiště | 7,80 | 4,35 | 34 | 15,0 | 510 | 0 | 100 | 01.led | | | | |
| | | | | | | | | | | | | | |
| 208 | schodiště | 13,80 | 4,45 | 61 | 15,0 | 930 | 0 | 100 | 01.led | | | | |
| 330 | schodiště | 13,80 | 3,90 | 54 | 15,0 | 810 | 0 | 100 | 01.led | | | | |
| | | | | | | | | | | | | | |
| | | | | Součet | | 2 250 | 0 | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | Zařízení číslo 3 - Větrání CHÚC B | | | | | | | | | | | | |
| 161 | schody | 8,70 | 4,35 | 38 | 15,0 | 570 | 0 | 100 | 01.led | | | | |
| 162 | chodba | 11,50 | 4,35 | 50 | 15,0 | 760 | 0 | 100 | 01.led | | | | |
| | | | | | | | | | | | | | |
| 246 | schodiště | 36,60 | 4,45 | 163 | 15,0 | 2 450 | 0 | 100 | 01.led | | | | |
| 344 | schodiště | 10,40 | 3,90 | 41 | 15,0 | 610 | 0 | 100 | 01.led | | | | |
| | | | | | | | | | | | | | |
| | | | | Součet | | 4 390 | 0 | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |
| | | | | | | | | | | | | | |